

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1493:117 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** \*Grinnell Fire Protection Systems, 835 Sharon Dr., Westlake OH 44145  
Contact: R.D. McDonnell (216) 871-9900

**DESIGN:** Model D5200-441 autoplex data-gathering panel. System components:

|              |                                |
|--------------|--------------------------------|
| D5200-442    | Autoplex data-gathering module |
| D5200-516    | Autoplex power supply          |
| 7845-001     | Autoplex transmitter           |
| 7845-001-001 | Autoplex transmitter           |
| 4281-301     | Auxiliary Relay Module         |

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model or catalog number and UL label.

**APPROVAL:** Listed as control unit accessories for use with Model AUTOCOMMAND II (ACII) (CSFM Listing No. 7165-1493:115) and Model 3800 series (CSFM Listing No. 7165-1493:111) fire alarm control units.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Formerly 7300-0077:110

\*Rev. 09-05-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 19, 2001**

*Listing Expires **June 30, 2002***

Authorized By:

**BEN HO**, Supervising Deputy  
Program Manager